



**PRODUCT NUMBER: 2091911**  
**ELECTROSOFT CLASS 1**

For electrical work with a maximal voltage of 7500 volts. To be used with leather protectors for mechanical protection.

**Honeywell**

## Overview

**Reference Number**

2091911

**Product Type**

Gloves

**Range**

Electrical Protection

**Line**

Latex

**Brand**

Honeywell

**Brand formerly known as**

ELECTROSOFT

**Industry**

- Energy or Electricity
- Maintenance
- Telecoms

**Product Use**

For electrical work with a maximal voltage of 7500 volts. To be used with leather protectors for mechanical protection.

## Features & Benefits

**Feature**

Beige natural latex insulating glove

Cut edge

Category RC

**Benefit**

COMFORT

Its ergonomic design combined with a lightly powdered interior increases the comfort by providing additional softness and allows the glove to be put on and taken off very easily.

RESISTANCE

The natural latex base offers high dielectric characteristics.

Its thickness (1.5mm) provides good dexterity while offering protection up to 7,500 volts.

**SAFETY**

His length protects a large part of the forearm.  
To be used with leather protectors for mechanical protection.

**Technical Description**

**Description**

CE CATEGORY : III Irreversible risks  
In accordance with standards :  
EN 60903-2003  
CEI 903-2002

**CHARACTERISTICS :**

Beige natural latex insulating glove  
Cut edge  
Category RC

**Product Technology**

Dipped Gloves

**Glove/liner color**

Beige

**Coating Type**

Latex

**Length**

41 cm

**Thickness**

1.5 mm

**Harmlessness**

In conformity with the European standards

**Dexterity**

Class 1

**Sizes**

8 to 11

**Packaging Label**

**Tagging**

CE HONEYWELL  
2091911 XX  
EN 60903-2003  
CEI 903-2002

**Certifications**

**E.C. Declaration of Conformity**

**EC Category PPE**

3

**Quality Assurance**

ISO 9001 / 2000

**EC Certificate Number**

7007

**EC Attestation**

EC Attestation

**EC Attestation Number**

7007

**Additional Information**

**User Information Sheet**

On the polybag

## Maintenance

**Life Cycle**

Gloves that are used frequently should be tested at intervals less than 6 month.

Gloves that are used only occasionally should be tested after each use and, in any case, at intervals of not more than 12 months.

Gloves held in stock should be retested at intervals not exceeding 12 months.

**Storage Information**

Store in original packaging (Opaque and anti-UV packaging used for protection and instructions for use). Do not compact or fold.

Do not expose to heat sources (sunlight, radiators, artificial light). Store between 10°C and 21°C.

**Care Instructions**

**Inspection :**

Before each use, carry out a visual inspection and check the glove inflation. Any puncture or perforation makes the gloves unusable.

**Precautions :**

Do not expose to solvents or chemicals that may cause deterioration. Do not use the glove when damp.

**Cleaning :**

Use water and soap. Dry below 65°C with ambient humidity.